

# AENOR Product Certificate

## Isolating valves for water supply



**B18/000007**

AENOR, Spanish Association for Standardization and Certification, certifies that the organization

### **ANGODOS, S.L.**

registered office	CL San Juan nº 21-23, Polígono Industrial El Palomo 28946 Fuenlabrada (Madrid - España)
supplies	Isolating valves for water supply
in compliance with	UNE-EN 1074-1:2001 (EN 1074-1:2000) UNE-EN 1074-1:2001 ERRATUM:2008 UNE-EN 1074-2/A1:2004 (EN 1074-2:2000/A1:2004) UNE-EN 1074-2:2001 (EN 1074-2:2000)
References	Specified in Annex to the Certificate
Production site	CL San Juan nº 21-23, Polígono Industrial El Palomo 28946 Fuenlabrada (Madrid - España)
Certification scheme	In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP B18.01
First issued on	2014-07-23
Validity date	2019-07-23

**AENOR** Asociación Española de  
Normalización y Certificación

Avelino BRITO  
Chief Executive Officer

**AENOR**

Asociación Española de  
Normalización y Certificación

Génova, 6. 28004 Madrid. España  
Tel. 902 102 201 – www.aenor.es

# AENOR Product Certificate

## Isolating valves for water supply



B18/000007

### Annex to Certificate

Trade Mark	Model	Type of valve	Type of flow	Type of seal	Type of ends	PN	Service temperatures	DN
ANGODOS	AG1-VC	BUTTERFLY	FULL BORE	RESILIENT	FLANGED	10/16	0 / 40 °C	100, 150, 200, 250, 300
ANGODOS	AG1-VC	BUTTERFLY	FULL BORE	RESILIENT	FLANGED	25	0 / 40 °C	100, 150, 200, 250, 300

**AENOR** Asociación Española de  
Normalización y Certificación

First issued on 2014-07-23  
Validity date 2019-07-23